## STATE OF WEST VIRGINIA Department of Environmental Protection Environmental Enforcement

## NOTICE OF VIOLATION

Violation No W23-47-020-TJC

To the Operator or Agent of:

Facility Name: **Parsons-Davis Core Borings** Permit No. **WVR112141** 

Permittee or Individual: **GREENMAN-PEDERSEN, INC.** 

Located at or near: **Parsons**, in **Tucker** County

Representative: **DOUGLAS ROBB** Date: 10/2/2023 Time: 10:15

Address / phone number: 11000 ROKEN LAND PARKWAY, SUITE 500, COLUMBIA, MD 21044 /

4108803055

Whereas, an inspection of the above named operation by the undersigned, duly authorized agent of the Secretary, at which the following described condition or practice exists, in violation of Chapter <u>22</u>, Article <u>11</u>, Section(s) <u>1</u> et. Seq. of the Code of West Virginia and/or Section(s) \_\_\_ of the Rules and Regulations and/or Section(s) <u>I.</u> of the Permit referenced above promulgated thereunder in that you: <u>Have violated the following terms and conditions of WV/NPDES General Water Pollution Control Permit No. WV0115924, Registration No. WVR112141:</u>

- 1. Section I.B.- GREENMAN-PEDERSEN, INC. failed to comply with the General Permit and approved Storm Water Pollution Prevention Plan (SWPPP). Several erosion control devices are not in place as detailed by the SWPPP.
  - a. Temporary drill access roads that were disturbed on sloping ground that lacked the 18" min. compost filter socks that are indicated in the approved SWPPP (plan sheet 13) were observed frequently from 5898+00 to 5920+00.
  - b. Temporary drill access roads that were disturbed on sloping ground and lacked installed water bars that are indicated in the approved SWPPP were observed from 5898+00 to 5920+00. Only one installed water bar was observed in this area (PAR-18), and it lacked the water bar outlet treatment indicated in the approved SWPPP (plan sheet 16).

The following corrective measures were discussed with you at the time of this inspection: Take measures to correct the aforementioned violations.

Within <u>20</u> days provide a written response to the inspector named below, at the address indicated, detailing the actions taken to abate this violation.

Received by:  Signature			
		Title	
Jim Coo			
Duly Authorized Agent /	(304)288-6219	tim.j.casto@wv.gov	
Inspector	Telephone	E-mail	

Send Response to the Inspector at the address indicated below:

WV Department of Environmental Protection Environmental Enforcement / WW 2031 Pleasant Valley Road; Fairmont, WV 26554